



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order ID: 042521227
Customer ID: UTAH51
Customer PO:
Project ID:

Attn: Jeff Perkins
Utah Division Of Air Quality
P.O. Box 144820
195 North 1950 West
Salt Lake City, UT 84114
Proj: Treasure Mountain MS - Boys Locker

Phone: (801) 536-4072
Fax: (801) 536-4099
Collected: 10/22/2025
Received: 10/23/2025
Analyzed: 10/23/2025

Summary Test Report for Asbestos Analysis of Bulk Material

Client Sample ID: Boys-Locker-1-Texture **Lab Sample ID:** 042521227-0001

Sample Description: Boys Locker Room Ceiling/Ceiling Texture

TEST	Analyzed	Color	Non-Asbestos		Asbestos	Comment
	Date		Fibrous	Non-Fibrous		
PLM	10/23/2025	White	0.0%	97.0%	3% Chrysotile	
400 PLM Pt Ct	10/23/2025	White	0.0%	98.3%	1.75% Chrysotile	

Client Sample ID: Boys-Locker-1-Drywall **Lab Sample ID:** 042521227-0001A

Sample Description: Boys Locker Room Ceiling/Ceiling Drywall

TEST	Analyzed	Color	Non-Asbestos		Asbestos	Comment
	Date		Fibrous	Non-Fibrous		
PLM	10/23/2025	Brown/Tan	18.0%	82.0%	None Detected	

Client Sample ID: Boys-Locker-2-Texture **Lab Sample ID:** 042521227-0002

Sample Description: Boys Locker Room Ceiling/Ceiling Texture

TEST	Analyzed	Color	Non-Asbestos		Asbestos	Comment
	Date		Fibrous	Non-Fibrous		
PLM	10/23/2025	White	0.0%	96.0%	4% Chrysotile	
400 PLM Pt Ct	10/23/2025	White	0.0%	98.8%	1.25% Chrysotile	

Client Sample ID: Boys-Locker-2-Drywall **Lab Sample ID:** 042521227-0002A

Sample Description: Boys Locker Room Ceiling/Ceiling Drywall

TEST	Analyzed	Color	Non-Asbestos		Asbestos	Comment
	Date		Fibrous	Non-Fibrous		
PLM	10/23/2025	Brown/Tan	18.0%	82.0%	None Detected	

Client Sample ID: Boys-Locker-3-Texture **Lab Sample ID:** 042521227-0003

Sample Description: Boys Locker Room Ceiling/Ceiling Texture

TEST	Analyzed	Color	Non-Asbestos		Asbestos	Comment
	Date		Fibrous	Non-Fibrous		
PLM	10/23/2025	White	0.0%	97.0%	3% Chrysotile	
400 PLM Pt Ct	10/23/2025	White	0.00%	99.25%	0.75% Chrysotile	

Client Sample ID: Boys-Locker-3-Drywall **Lab Sample ID:** 042521227-0003A

Sample Description: Boys Locker Room Ceiling/Ceiling Drywall

TEST	Analyzed	Color	Non-Asbestos		Asbestos	Comment
	Date		Fibrous	Non-Fibrous		
PLM	10/23/2025	Brown/White	15.0%	85.0%	None Detected	



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order ID: 042521227
Customer ID: UTAH51
Customer PO:
Project ID:

Summary Test Report for Asbestos Analysis of Bulk Material

Analyst(s):

Emilie Kalbach PLM (4)
400 PLM Pt Ct (2)
Jannat Fareen PLM (2)
400 PLM Pt Ct (1)

Reviewed and approved by:

Samantha Sweeney, Laboratory Manager
or Other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This is a summary report; official reports are available on LabConnect or upon request and relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. The above analyses were performed in general compliance with Appendix E to Subpart E of 40 CFR (previously EPA 600/M4-82-020 "Interim Method") but augmented with procedures outlined in the 1993 ("final") version of the method. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government. Non-friable organically bound materials present a problem matrix and therefore EMSL recommends gravimetric reduction prior to analysis. Unless requested by the client, building materials manufactured with multiple layers (i.e. linoleum, wallboard, etc.) are reported as a single sample. Estimation of uncertainty is available on request.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NVLAP Lab Code 101048-0, AIHA LAP, LLC-IHLAP Lab 100194, PA ID# 68-00367, LA #04127

Initial report from: 10/23/2025 14:47:24