

Table 2
SUMMARY OF ANALYTICAL RESULTS IN SOILS - TCLP EVALUATION
Multi-Use Sports Complex Construction
2530 Kearns Boulevard
Park City, Utah 84060
 Results in milligrams per liter (mg/L)

Sample Name	Sample Type	Date	Metals (mg/L)							
			Arsenic	Barium	Cadmium	Chromium	Lead	Selenium	Silver	Mercury
PCSD-FTG-01	5-point composite	2/12/2026	<0.50	0.61	0.165	<0.050	9.10	<0.30	<0.05	<0.0020
PCSD-FTG-02	5-point composite	2/12/2026	<0.50	0.36	0.102	<0.050	21.80	<0.30	<0.05	<0.0020
PCSD-FTG-03	5-point composite	2/12/2026	<0.50	0.56	0.112	<0.050	3.09	<0.30	<0.05	<0.0020
PCSD-FTG-04	5-point composite	2/12/2026	<0.50	0.40	0.311	<0.050	24.90	<0.30	<0.05	<0.0020
PCSD-FTG-05	5-point composite	2/12/2026	<0.50	0.33	0.121	<0.050	8.10	<0.30	<0.05	<0.0020
PCSD-FTG-06	5-point composite	2/12/2026	<0.50	0.57	0.073	<0.050	2.51	<0.30	<0.05	<0.0020
PCSD-FTG-07	5-point composite	2/12/2026	<0.50	0.64	0.068	<0.050	0.84	<0.30	<0.05	<0.0020
PCSD-FTG-DUP-01	5-point composite	2/12/2026	<0.50	0.54	0.099	<0.050	3.44	<0.30	<0.05	<0.0020
<i>40 CFR 261.24 EPA TCLP Limit (mg/L)¹</i>			5.0	100	1.0	5.0	5.0	1.0	5.0	0.2

mg/L - milligrams per liter
 EPA - Environmental Protection Agency
 TCLP - Toxicity Characteristic Leaching Procedure
BOLD - exceeds the EPA TCLP Limit

¹ - 40 CFR 261.24 cited for regulatory limits (mg/L) for toxic characteristic hazardous waste based on U.S. EPAs TCLP Method 1311.